



## NOTES:

- ACOUSTIC LINED UNIT AS STANDARD.
- LEFT HAND UNIT AS DRAWN, RIGHT HAND OPPOSITE HAND, (HEATING AND COOLING CONNECTIONS REVERSED SEE SCRAP SIDE VIEW OF RIGHT HAND UNIT). UNITS ARE HANDED LOOKING INTO THE DISCHARGE OF THE UNIT, WITH THE UNIT IN ITS INSTALLED ORIENTATION. THE ABOVE UNIT IS DETAILED AS LEFT HAND COIL CONNECTIONS.

SPIGOT POSITIONS ARE IDENTIFIED FROM LEFT TO RIGHT WHEN LOOKING INTO THE DISCHARGE, WITH THE UNIT IN ITS INSTALLED ORIENTATION. SPIGOT POSITIONS ARE REGARDLESS OF COIL TAIL HANDINGS.

- FILTER(S) CAN BE EITHER SIDE REMOVAL OR DROP DOWN AND SLIDE OUT.

- UNIT FIXINGS (BY OTHERS) TO INCLUDE LARGE WASHERS, Ø 32 MAXIMUM. ALTERNATIVELY ISOLATION MOUNTS COMPLETE WITH WASHERS ARE AVAILABLE FROM DIFFUSION.

- UNIT ACCESS REQUIREMENTS: IT IS RECOMMENDED THAT FOR EFFICIENT SERVICEABILITY AND MAINTENANCE OF THESE FAN COIL UNITS THE MINIMUM SITE ACCESS SHOULD BE AS DETAILED ABOVE.

- KEY TO ABBREVIATIONS: CLG = COOLING HTG = HEATING ID = INSIDE DIAMETER OD = OUTSIDE DIAMETER OHC = OVERHEAT CUTOUT RESET BUTTON (REQUIRED ON ELECTRIC HEAT UNITS ONLY).

- GENERIC DRAWING: WEIGHTS SHOWN DO NOT INCLUDE EXTENDED DRIP TRAY AND VALVES OR, PUMP ASSEMBLY.

ACCESS REQUIREMENTS						Ø 197 SPIGOTS		
UNIT	WEIGHT kg	A	B	C	D	S SPIGOT PITCH (TYP.)	TOTAL No. OFF INCLUDING SIDES	SPIGOT POSITIONS REGARDLESS OF HANDING FOR SCHEDULE PURPOSES NTS.
04/1	44	565	530	503	1150	250	4	
06/1	54	715	680	653	1300	350	4	
08/1	66	915	880	853	1500	350	4	
08/2	73	915	880	853	1500	350	4	
10/1	77	1115	1080	1053	1700	350	5	
10/2	84	1115	1080	1053	1700	350	5	
12/2	96	1315	1280	1253	1900	350	5	
14/2	108	1515	1480	1453	2100	350	6	
14/3	108	1515	1480	1453	2100	350	6	
16/2	119	1715	1680	1653	2300	350	6	
16/3	119	1715	1680	1653	2300	350	6	
18/3	129	1915	1880	1853	2500	350	7	
18/4	141	1915	1880	1853	2500	350	7	

REV.	MOD.NO.	DATE	DRN				ALL DIMENSIONS IN mm THIRD ANGLE PROJECTION	DRAWING SCALE: 1:1	PRINT SCALE: N.T.S.	DRAWN MW	
5		21-05-25	MW				METALWORK TOLERANCES UNLESS OTHERWISE STATED: DIMENSIONAL ±0.5mm ANGULAR ±1°	MATERIAL:		DATE 24-02-23	TITLE: GENERAL ARRANGEMENT HIGHLINE 235 DEEP FAN COIL UNIT RANGE C/W 600 LONG ATTENUATORS AND Ø 197 DISCHARGE PLENUM HL235-WHCH-04-06-08-10-12-14-16-18-60A+60ACP
4		26-09-23	MW							CHECKED	
3		25-07-23	MW							DATE	
2		28-03-23	MW							APP'D	
1	REQ9690	09-03-23	MW				G.A. TOLERANCES UNLESS OTHERWISE STATED: DIMENSIONAL ±4mm ANGULAR ±1°	FINISH:		DATE	JOB: STANDARD OPTION
										DRG.NO.	A1/40533

Diffusion

Address: 47 Central Avenue, West Molesey, Surrey, KT8 2QZ  
Telephone: +44 (0) 20 8783 0033 Email: cooling@diffusion-group.com  
Website: www.diffusion-group.com