



					ACCESS REQUIREMENTS	Ø 197 SPIGOTS		
UNIT	WEIGHT kg	A	B	C	D	S SPIGOT PITCH (TYP).	TOTAL No. OFF INCLUDING SIDES	SPIGOT POSITIONS REGARDLESS OF HANDLING FOR SCHEDULE PURPOSES NTS.
04/1	39	565	530	503	1150	250	4	
06/1	48	715	680	653	1300	350	4	
08/1	59	915	880	853	1500	350	4	
08/2	66	915	880	853	1500	350	4	
10/1	69	1115	1080	1053	1700	350	5	
10/2	76	1115	1080	1053	1700	350	5	
12/2	86	1315	1280	1253	1900	350	5	
14/2	98	1515	1480	1453	2100	350	6	
14/3	98	1515	1480	1453	2100	350	6	
16/2	107	1715	1680	1653	2300	350	6	
16/3	107	1715	1680	1653	2300	350	6	
18/3	116	1915	1880	1853	2500	350	7	
18/4	128	1915	1880	1853	2500	350	7	

REV.	MOD.NO.	DATE	DRN							ALL DIMENSIONS IN mm THIRD ANGLE PROJECTION	DRAWING SCALE: 1:1	PRINT SCALE: N.T.S.	DRAWN	MW	<div>Diffusion</div> <div>Address: 47 Central Avenue, West Molesey, Surrey, KT8 2QZ Telephone: +44 (0) 20 8783 0033 Email: cooling@diffusion-group.com Website: www.diffusion-group.com</div>				
2	265 WHEN PUMP FITTED AND NOTE 7 ADDED	21-05-25	MW							METALWORK TOLERANCES UNLESS OTHERWISE STATED: DIMENSIONAL ±0.5mm ANGULAR ±1°	MATERIAL:		DATE 19-07-23		TITLE: GENERAL ARRANGEMENT HIGHLINE 235 DEEP FAN COIL UNIT RANGE C/W FILTER RETURN, 900 LONG DISCHARGE ATTENUATOR AND Ø 197 PLENUM HL235-WHCH-04-06-08-10-12-14-16-18"FR+90ACP				
1	REQ10308	19-07-23	MW							CHECKED			DATE			APP'D	JOB: STANDARD OPTION		
										G.A. TOLERANCES UNLESS OTHERWISE STATED: DIMENSIONAL ±4mm ANGULAR ±1°	FINISH:		DATE	DRG.NO.	A1/40922				