



UNIT	WEIGHT kg	A	B	C	D	ACCESS REQUIREMENTS		$\phi 247$ SPIGOTS (AS DRAWN) STANDARD		$\phi 197$ SPIGOTS (OPTION)	
						S	PITCH (TYP.)	TOTAL No. OFF INCLUDING SIDES	S	PITCH (TYP.)	TOTAL No. OFF INCLUDING SIDES
04/1	38	565	530	503	1150	-		3	250	4	
06/1	45	715	680	653	1300	350		4	350	4	
08/1	53	915	880	853	1500	350		4	350	4	
08/2	59	915	880	853	1500	350		4	350	4	
10/1	62	1115	1080	1053	1700	350		5	350	5	
10/2	68	1115	1080	1053	1700	350		5	350	5	
12/2	78	1315	1280	1253	1900	350		5	350	5	
14/2	87	1515	1480	1453	2100	350		6	350	6	
14/3	90	1515	1480	1453	2100	350		6	350	6	
16/2	95	1715	1680	1653	2300	350		6	350	6	
16/3	98	1715	1680	1653	2300	350		6	350	6	
18/3	107	1915	1880	1853	2500	350		7	350	7	
18/4	113	1915	1880	1853	2500	350		7	350	7	

REV.	MOD.NO.	DATE	DRN					ALL DIMENSIONS IN mm THIRD ANGLE PROJECTION	DRAWING SCALE: 1:1	PRINT SCALE: N.T.S.	DRAWN	MW	Diffusion Address: 47 Central Avenue, West Molesey, Surrey, KT8 2QZ Telephone: +44 (0) 20 8783 0033 Email: cooling@diffusion-group.com Website: www.diffusion-group.com	
1	REQ9690	14-04-25	MW					METALWORK TOLERANCES UNLESS OTHERWISE STATED: DIMENSIONAL ± 0.5 mm ANGULAR $\pm 1^\circ$			DATE	14-04-25		
								G.A. TOLERANCES UNLESS OTHERWISE STATED: DIMENSIONAL ± 4 mm ANGULAR $\pm 1^\circ$			CHECKED		TITLE: GENERAL ARRANGEMENT HIGHLINE 275 DEEP FAN COIL UNIT RANGE C/W 300 LONG INLET ATTENUATOR AND $\phi 247$ or $\phi 197$ (OPTION) DISCHARGE PLENUM HL275-WHCH-04-06-08-10-12-14-16-18-30A+CP	
											DATE			
											APP'D		JOB: STANDARD	
											DATE		DRG.NO.	A1/42387